

This declaration of conformity is issued under the sole responsibility of

Rosemount Inc.
6021 Innovation Blvd
Shakopee, MN 55379
USA

that the following products,

Rosemount™ 3144P Temperature Transmitter

comply with the provisions of the European Union Directives, including the latest amendments, valid at the time this declaration was signed.

 July 18, 2025 | Mark Lee | Vice President, Quality | Boulder, CO, USA
(signature & date of issue) (name) (function) (place of issue)

Authorized Representative in Europe:
Emerson S.R.L., company No. J12/88/2006
Emerson 4 street, Parcul Industrial
Tetarom II, Cluj-Napoca 400638, Romania

Regulatory Compliance Shared Services Department
Email: europeproductcompliance@emerson.com Phone: +40 374 132 035

ATEX Notified Bodies for EU Type Examination Certificates:

DEKRA Certification B.V [Notified Body Number: 0344]

Meander 1051, 6825 MJ Arnhem
P.O. Box 5185
6802 ED Arnhem The Netherlands

ATEX Notified Body for Quality Assurance:

SGS Fimko Oy [Notified Body Number: 0598]

Takomotie 8
FI-00380 Helsinki
Finland

EMC Directive (2014/30/EU)

Harmonized Standard:
EN 61326-1: 2013
EN 61326-2-3: 2013

RoHS Directive (2011/65/EU)

Harmonized Standards:
EN IEC 63000:2018

Rosemount 3144P Temperature Transmitter (HART Output)

ATEX Directive (2014/34/EU)

BAS01ATEX1431X – Intrinsic Safety Certificate

Equipment Group II, Category 1 G

Ex ia IIC T5 Ga

Ex ia IIC T6 Ga

Harmonized Standards:

EN IEC 60079-0:2018

EN 60079-11:2012

BAS01ATEX3432X – Type n or Increased Safety Certificate

Equipment Group II, Category 3G

Ex nA IIC T5 Gc or Ex ec IIC T5 Gc

Ex nA IIC T6 Gc or Ex ec IIC T6 Gc

Harmonized Standards:

EN IEC 60079-0:2018

EN IEC 60079-7:2015+A1:2018

EN 60079-15:2010

Rosemount 3144P Temperature Transmitter (Fieldbus Output)**Baseefa03ATEX0708X – Intrinsic Safety Certificate**

Equipment Group II, Category 1 G

Ex ia IIC T4 Ga

Harmonized Standards:

EN IEC 60079-0:2018

EN 60079-11:2012

Baseefa03ATEX0709X – Type n or Increased Safety Certificate

Equipment Group II, Category 3G

Ex nA IIC T5 Gc or Ex ec IIC T5 Gc

Harmonized Standards:

EN IEC 60079-0:2018

EN IEC 60079-7:2015+A1:2018

EN 60079-15:2010

Rosemount 3144P Temperature Transmitter (all Output Protocols)**DEKRA 19ATEX0076X – Dust Certificate**

Equipment Group II, Category 2 D

Ex tb IIIC T130°C Db

Harmonized Standards:

EN IEC 60079-0:2018

EN 60079-1:2014

EN 60079-31:2014

DEKRA 19ATEX0076X – Flameproof

Equipment Group II, Category 2 G

Ex db IIC T6...T1 Gb

Harmonized Standards:

EN IEC 60079-0:2018

EN 60079-1:2014

EN 60079-31:2014